WARRANTY CARD

Taro

॥ ಶ್ರೀ ಗಂಗಮ್ಮ ಕೃಪಾ ॥

ಸಮೃದ್ಧಿ

Smt. Kavitha Singh
Mo. 9964702826

Samrudhi Ground Water Consultant

46, Gangamma Temple Street, Near Gangamma Temple, Malleswaram, Bangaloare-03

Ref. :.....

Date : 23/6/16

REPORT ON GROUND WATER INVESTIGATION

Name B.B.M.P Ward No (2)

Address Kenchanalli Shiva temple
Muneshwara temple

Location Shiva temple

Topography

Soil Type Boulders

Rock Type Black & white

RECOMMENDATIONS

Nos.			
Depth	1000ft	Depth	1200ft
Casing	200ft	Casing	250ft
Yield	2 inc	Yield	2 1/2 inc
Aquifers		Aquifers	

Remarks good water

Note : The Survey was carried out by this divining / Geophysical method of Surveying is with our good knowledge and experience, However no guarantee of water will be given

ನೀರು ಅತ್ಯಮೂಲ್ಯ, ಅದನ್ನು ಸಂರಕ್ಷಿಸಿ... Water is precious, Conserve it... ಗಿಡ ಬೆಳೆಸಿ, ಮರಗಳನ್ನು ಉಳಿಸಿ

Smt. Kavitha Singh

WARRANTY CARD

Taro

BOREWELL COMPLETION REPORT

VINAYAKA ENTERPRISES

Borewell Drilling Contractors

Mobile : +91 9342202932 / 9343202932

No. 9, Bhadrappa Layout, Bhadrappa Compound, Near Hebbal, Ring Road, Bangalore 560094

No. : 118

Date : 6/7/16

1. Customer's Name and Address with Telephone No. : B.B.M.P. Ward No 20 (2) Krishna Murthy Lotta Kondappa Layout

2. Well Location : Krishnamurthy Lotta

3. Total Well Depth / Drilled in Ft. : 1100 — 1200ft.

4. Casing Erected in Ft. : 160 — 200ft.

5. Water Struck at the Depth of : 700ft.

6. Total Yield (Measuring method "V" Norch : 2 - 2 ½ / Inches on "V" Norch)

7. Formation of Soil/Well Water Condition : Boulders/Silt/Loose Soil/Clear Clear

8. At the Depth of : 500ft

9. Recommended to use Jet Pump / Air Compressor / Submersible /Hand Pump

The Borewell was drilled in accordance with the company terms and conditions and handed over to customer in good/ satisfied / Party agreed conditions.

Once the well handed over to party, company is no way responsible for further developments if anything in the well or what so ever.

Party's Signature

I owner of the Well / (Authorised signatory) fully understood the terms and conditions and the well completion report, I also fully understood the quality and quantity of water from the well duly depend upon the nature / formation of ground water and the drilling agency no way responsible for further occurrence / Changes in the bore with full satisfaction. I hereby endorse my signature.

For VINAYAKA ENTERPRISES

N. Ravi

Party's Signature

Manager / Proprietor

Smt. Kavitha Singh

BOREWELL

॥ ಶ್ರೀ ಗಂಗಮ್ಮ ಕೃಪಾ ॥

ಸಮೃದ್ಧಿ

Smt. Kavitha Singh.
Mo. 9964702826

Samrudhi Ground Water Consultant

46, Gangamma Temple Street, Near Gangamma Temple, Malleswaram, Bangaloare-03

Ref. :.....

Date : 23/6/16

REPORT ON GROUND WATER INVESTIGATION

Name: B.B.M.P Ward No (2).

Address: Krishnamurthy Lotta Kondappa layout.

Location: KrishnaMurthy Lotta

Topography:

Soil Type: Cl Boulder Soil.

Rock Type: Black & White.

RECOMMENDATIONS

Nos.			
Depth	1100ft	Depth	1200ft
Casing	180ft	Casing	220ft
Yield	2	Yield	2 inc
Aquifers		Aquifers	

Remarks: Well Water

Note : The Survey was carried out by this divining / Geophysical method of Surveying is with our good knowledge and experience, However no guarantee of water will be given

ನೀರು ಅತ್ಯಮೂಲ್ಯ, ಅದನ್ನು ಸಂರಕ್ಷಿಸಿ... Water is precious, Conserve it... ಗಿಡ ಬೆಳೆಸಿ, ಮರಗಳನ್ನು ಉಳಿಸಿ

Smt. Kavitha Singh

Water Diviner

WARRANTY CARD

Taro

BOREWELL COMPLETION REPORT

VINAYAKA ENTERPRISES

Borewell Drilling Contractors

Mobile : +91 9342202932 / 9343202932

No. 9, Bhadrappa Layout, Bhadrappa Compound, Near Hebbal, Ring Road, Bangalore 560094

No. : 119

Date : 25/4/11

1. Customer's Name and Address with Telephone No. : B.B.M.P Ward No (2). Venugopal Swamy Temple Kodi Bisle

2. Well Location : Venugopal. Temple.

3. Total Well Depth / Drilled in Ft. : 1000ft - 1200ft.

4. Casing Erected in Ft. : 160ft - 200ft.

5. Water Struck at the Depth of : 750ft.

6. Total Yield (Measuring method "V" Norch : 2 - 2½ cm / Inches on "V" Norch)

7. Formation of Soil/Well Water Condition : Boulders/Silt/Loose Soil/Clear Clear.

8. At the Depth of : 680ft.

9. Recommended to use Jet Pump / Air Compressor / Submersible /Hand Pump

The Borewell was drilled in accordance with the company terms and conditions and handed over to customer in good/ satisfied / Party agreed conditions.

Once the well handed over to party, company is no way responsible for further developments if anything in the well or what so ever.

Party's Signature

I, owner of the Well / (Authorised signatory) fully understood the terms and conditions and the well completion report, I also fully understood the quality and quantity of water from the well duly depend upon the nature / formation of ground water and the drilling agency no way responsible for further occurrence / Changes in the bore with full satisfaction. I hereby endorse my signature.

For VINAYAKA ENTERPRISES

N. Ramesh

Manager / Proprietor

Party's Signature

WARRANTY CARD

॥ ಶ್ರೀ ಗಂಗಮ್ಮ ಕೃಪಾ ॥

Smt. Kavitha Singh.
Mo. 9964702826

ಸಮೃದ್ಧಿ

Samrudhi Ground Water Consultant

46, Gangamma Temple Street, Near Gangamma Temple, Malleswaram, Bangaloare-03

Date : 10/2/14

Ref. :

REPORT ON GROUND WATER INVESTIGATION

Name: B.B.M.P. Ward No (2).

Address: Venugopal Swamy temple Kote side

Location: Venugopal Swamy temple.

Topography:

Soil Type: loose Soil.

Rock Type: Black & white.

RECOMMENDATIONS

Nos.			
Depth	1000ft	Depth	1100ft.
Casing	160ft	Casing	200ft.
Yield	2 ins.	Yield	2 ins
Aquifers		Aquifers	

Remarks: well water

Note : The Survey was carried out by this divining / Geophysical method of Surveying is with our good knowledge and experience, However no guarantee of water will be given

ನೀರು ಅತ್ಯಮೂಲ್ಯ, ಅದನ್ನು ಸಂರಕ್ಷಿಸಿ... Water is precious, Conserve it... ಗಿಡ ಬೆಳೆಸಿ, ಮರಗಳನ್ನು ಉಳಿಸಿ

Smt. Kavitha Singh

Water Diviner

BOREWELL COMPLETION REPORT

VINAYAKA ENTERPRISES

Borewell Drilling Contractors

Mobile : +91 9342202932 / 9343202932

No. 9, Bhadrappa Layout, Bhadrappa Compound, Near Hebbal, Ring Road, Bangalore 560094

No. : 120 Date : 8/8/14

1. Customer's Name and Address with Telephone No. : B.B.M.P. Ward No (2). Vellanka. lake. Road. Kodi Road.
2. Well Location : Goodwill School.
3. Total Well Depth / Drilled in Ft. : 900 – 100ft.
4. Casing Erected in Ft. : 160ft – 200ft.
5. Water Struck at the Depth of : 780ft.
6. Total Yield (Measuring method "V" Norch : 2"/hr. / Inches on "V" Norch)
7. Formation of Soil/Well Water Condition : Boulders/Silt/Loose Soil/Clear Clear.
8. At the Depth of : 600ft.
9. Recommended to use Jet Pump / Air Compressor / Submersible /Hand Pump

The Borewell was drilled in accordance with the company terms and conditions and handed over to customer in good/ satisfied / Party agreed conditions.

Once the well handed over to party, company is no way responsible for further developments if anything in the well or what so ever.

Party's Signature

I owner of the Well / (Authorised signatory) fully understood the terms and conditions and the well completion report, I also fully understood the quality and quantity of water from the well duly depend upon the nature / formation of ground water and the drilling agency no way responsible for further occurrence / Changes in the bore with full satisfaction. I hereby endorse my signature.

For VINAYAKA ENTERPRISES

N. Ramesh

Manager / Proprietor

Party's Signature

Smt. Kavitha Singh

RRANTY CARD

Taro

॥ ಶ್ರೀ ಗಂಗಮ್ಮ ಕೃಪಾ ॥

ಸಮೃದ್ಧಿ

Smt. Kavitha Singh
Mo. 9964702826

Samrudhi Ground Water Consultant

46, Gangamma Temple Street, Near Gangamma Temple, Malleswaram, Bangaloare-03

Ref. :.....

Date : 7.1.16.....

REPORT ON GROUND WATER INVESTIGATION

Name B.B.M.P. Ward No 2.

Address Yelhanka Lake Kodi Road

Location Good will School.

Topography

Soil Type Loose Soil

Rock Type Black & White

RECOMMENDATIONS

Nos.			
Depth	900ft	Depth	1000ft.
Casing	160 ft	Casing	200ft.
Yield	2 inc	Yield	2½ inc.
Aquifers		Aquifers	

Remarks well drinking water.

Note : The Survey was carried out by this divining / Geophysical method of Surveying is with our good knowledge and experience, However no guarantee of water will be given

ನೀರು ಅತ್ಯಮೂಲ್ಯ, ಅದನ್ನು ಸಂರಕ್ಷಿಸಿ... Water is precious, Conserve it... ಗಿಡ ಬೆಳೆಸಿ, ಮರಗಳನ್ನು ಉಳಿಸಿ

Smt. Kavitha Singh